



Rohr Bypass  
dringend empfohlen!  
Notwendig vor Inbetriebnahme und während Service- / Wartungsarbeiten!

pipe bypass  
urgently recommended!  
Necessary before commissioning and during service / maintenance works!

Sedimentation sedimentation    Belebung 1 aeration    Belebung 2 aeration    Filtration filtration    Filtratschacht filtrate shaft    Servicewasser service water

**GreenLife**

GreenLife GmbH  
Sacktannen 1a  
19057 Schwerin

Tel. +49 385 77337-0  
Fax. +49 385 77337-33  
info@greenlife.info

all dimensions in mm  
alle Angaben in mm  
Toleranz +/-3%

creator date  
Siggelkow 17.01.2023

All tank-connections are displayed as example. They are not pre-installed and have to be adapted in place.  
Alle Tankverbindungen sind beispielhaft dargestellt. Sie sind nicht vorinstalliert und müssen vor Ort angepasst werden.

\* Additional equipment required  
Technical developments and changes in individual items, as well as errors, misprint and price alterations reserved. Photos and drawings are nonbinding. Depending on the technology, minor dimensions, weight and color variations may occur.  
optionales Zubehör erforderlich  
Technische Weiterentwicklungen und Änderungen der einzelnen Artikel, sowie Irrtümer, Druckfehler und Preisänderungen vorbehalten. Fotos und Zeichnungen sind unverbindlich. Technologisch bedingt können geringfügige Maß-, Gewichts- und Farbabweichungen auftreten.

Produktbezeichnung / product description:  
Grauwasser-Recycling-Anlage 2.000 l/d indoor  
greywater-recycling-system 2.000 l/d indoors

Anlagentyp / type of system:  
GWI 2.3-2.000

Art.-Nr. / item no.:  
G0002396

Zeichnungstyp / type of drawing:  
R&I Fließschema / P&I flow diagram